



Microbiology Testing Laboratory
An ISO 9001:2015 Certified Company

Aleap Common Facilities Area,
Survey No. 342, Aleap Industrial Estate
Near Pragathi Nagar, Opp JNTU Lane,
Kukatpally, Hyderabad - 500 072
Mobile : 98485 94359, 96666 91334
Website: www.mptri.com
E-mail : mptri@gmail.com, mptri@rediffmail.com

TEST REPORT

Issued to:
M/s. Vignan Vidyalayam,
Sy No: 484/A, AA, E, EE, Chinnakanjarla (Vill),
Patancheru (Mdl), Sangareddy (D1), Telangana.

Report No.: MPTRI/W/1001-280/I
Issue Date: 16th June, 2025
Customer Ref.: Nil
Ref. Date : 12th June, 2025

Sample Particulars: RO Water

Qty.: 1 X 1000 ml. Type of Packing: Sterilized Bottles. Test Reqd.: Important Parameters
Date of starting of analysis: 12th June, 2025 Date of completion of analysis: 16th June, 2025

TEST RESULTS

Essential Characteristics	Units	Result	Desirable Limits as per IS:10500
Colour	Hazen. Max	<1.0	5.0
Odour		Agreeable	Agreeable
Taste		Agreeable	Agreeable
Turbidity.	NTU, Max	<1.0	1.0
pH	--	6.70	6.50-8.50
Total Hardness (as CaCO ₃)	mg/l, Max	25	200
Iron (as Fe)	mg/l, Max	<0.01	1.0
Chloride (as Cl)	mg/l, Max	14.16	250
Fluoride (as F)	mg/l, Max	<0.1	1.0
Desirable Characteristics			
Dissolved Solids	mg/l, Max	51	500
Calcium (as Ca)	mg/l, Max	10.04	75
Magnesium (as Mg)	mg/l, Max	0.42	30
Copper (as Cu)	mg/l, Max	<0.01	0.05
Manganese (as Mn)	mg/l, Max	<0.01	0.1
Sulphate (as SO ₄)	mg/l, Max	0.60	200
Nitrate (as NO ₃)	mg/l, Max	<0.01	45
Alkalinity	mg/l, Max	25	200
Aluminum (as Al)	mg/l, Max	<0.01	0.03
Bacteriological Characteristics			
Coliforms/100ml	CFU	Absent	Absent
E.coli/100ml	CFU	Absent	Absent

Remarks: The above analyzed test results are in the Desirable limits as per Drinking water specification IS: 10500-2012.

SWATHI
AUTHORISED SIGNATORY



26/6/25

HEAD MASTER
VIGNAN VIDYALAYAM
Chinna Kanjerla Village
Daultabad Road, Patancheru (M)
SANGAREDDY DIST.

Scanned with OKEN Scanner



Annexure C

PROFORMA FOR SAFE DRINKING WATER HYGIENIC SANITARY CONDITION CERTIFICATE

No. 02/2025

Dated 20/06/2025

It is certified that an inspection team headed by G. Ramakrishna, Panchayat Secretary from M.P.T.R.I. Microbiology Testing Laboratory An ISO9001:2015 Certified Company have inspected the Vignan Vidyalayam, Sy No 484/A, AA, E, EE, Chinnakanjarla(V), Patancheru(M), Sangareddy (D) On 20/06/2025 and on the basis of Water Test Report (Attached) bearing no MPTRI/W/1001-280/1 dated 16/06/2025 from MPTRI Labs, Sy No 342, Aleap Industrial Estate, Near Pragathi Nagar, Kukatpally, Hyderabad, certified that the Vignan Vidyalayam, Sy.No.484/A,AA,E,EE, Chinnakanjarla(V), Patancheru(M), Sangareddy(D) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U T. Govt.

This certificate is valid till 19/06/2026

Signature with Seal

G. Ramakrishna
Panchayat Secretary
Gram Panchayat Chinnakanjarla
Mdl. Patancheru, Sangareddy Dist

To
The Principal,
Vignan Vidyalayam,
Sy No 484/A, AA, E, EE,
Chinnakanjarla(V),
Patancheru(M),
Sangareddy(D)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

20/6/25